



Fire Safety Certificate (RENEW)  
Punjab Fire and Emergency Service  
(Fire Station:- Moga)

FastTrack  
**PUNJAB**  
Portal

**Pin:260422050**

**ApplicationId:2604357419**

**Dated 11-May-2026**

**Certificate No:-PBIP-(FIRE) 2026/5710**

**Valid Till:- 10-May-2029 ( 3)year**



Certified that the building on the name of AKAL ACADEMY PURANEWALA, is situated at Akal Academy Puranewala VPO Puranewala Tehsil & Distt Moga Pin 142038 Punjab, owned by Jagjit Singh, is comprised of a total covered area of 3380 sq. mtrs and the height of the building is 14 meters including a total of 4 floor(s) and 0 basement(s).

This building is inspected by officer of Punjab Fire and Emergency Service and found complied with the firefighting system requirements of National Building Code, 2005 / 2016, Part-4. The site inspection was carried out in the presence of Jagjit Singh. This building / site is fit for occupancy Group Educational-(B) (this occupancy group is as per National Building Code, 2016 Part-4). This certificate is issued with the following conditions and this certificate is valid for 3 year.

Issued on 11-May-2026 at -Moga

**General Conditions:**

1. Owner/Occupier is responsible to maintain the Fire Fighting System and Life Safety Systems in the working condition 24X7 at all the times.
2. No Alteration / addition / Change in Covered Area, Height of Building & Type of Occupancy is allowed..
3. Owner/Occupier shall ensure the periodic Fire Safety Training on Fire Prevention & Operationing of Fire Fighting Systems to among all the occupants and maintain records of the same. Owner/Occupier shall also ensure to organise Mock Drill Biannually and maintain the records of the same
4. Officer of Punjab Fire and Emergency Service is authorised to inspect your building as per the procedure defined in the Punjab Fire and Emergency Service Act, 2024 and in case of any deficiency or irregularity is found in the Fire Fighting System & Life Safety Systems, the officer of Punjab Fire and Emergency Service may initiate the appropriate action as deemed fit under the provisions of the Punjab Fire and Emergency Service Act, 2024, which may lead to imposing penalty or cancellation of Fire Safety Certificate etc.
5. Owner/Occupier shall apply for the renewal of fire safety certificate at least one month prior to expiry of this certificate.
6. In view of any Special Risks is Involved or life safety of the occupants, the approving Authority of this Fire Safety Certificate can issue Special Conditions separately through an official letter in continuation of this certificate.

\* Above Details cannot be used as ownership proof.

\* This is digitaly created cerificate, no signature is needed.