

PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION


CERTIFICATE

No: 728

Date: 04-06-2026

It is certified that an inspection team headed by Sh. AMRITPAL SINGH SDE, WATER SUPPLY AND SANITATION SUB DIVISION NO. 2 MOGA (Name of Officers with designation) from Department of Water Supply and Sanitation, Moga (Name of Department/Office) inspected the Akal Academy Puranewala VPO Puranewala, Tehisl & Distt. Moga, Punjab (Name & Address of the School/Business/Institution) On 14/05/2026 and found that the Akal Academy Puranewala VPO Puranewala, Tehisl & Distt. Moga, Punjab (Name of School/Business/Institution) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition the school building.

The above certificate is valid for a period of 1 year (2026-27).


Signature with Seal: Sub Division Engineer
Water Supply & Sanitation
Sub Division No. 2, Moga

Name : Sh. AMRITPAL SINGH

Designation: Sub Divisional Engineer,
Water Supply and Sanitation,
Sub Division No. 2, Moga

To,

Akal Academy Puranewala

VPO Puranewala, Tehisl & Distt. Moga, Punjab

(Name & Address of the Institution)

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)
rwtlmoga@gmail.com

To,

Akal Academy Puranewala
VPO Purane Wala Tehsil & Distt Moga (Punjab)


No.: RWTLMOG/2627/00090 Dated : 28/04/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Ref. No. - Pum/175 Dated: 16/04/2026

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 24/04/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Moga

D/A : Test Report



**Authorized Signatory
For, Regional Water Testing Lab
Moga**

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)

rwtlmoga@gmail.com

TEST REPORT						
Name & Address of Customer : Akal Academy Puranewala VPO Purane Wala Tehsil & Distt Moga (Punjab)			Customer Reference No.		No : Ref. No. - Pum/175 Dated : 16/04/2026	
			Sample Submitted by		Harpreet singh	
			Date of Sample Receipt		24/04/2026	
			Analysis Starting Date		25/04/2026	
			Analysis completion Date		27/04/2026	
Discipline : Chemical Testing, Bacteriological Testing			Group: Water			
ULR No.:				Sample Type :		Water
Test Report No.:		RWTLMOG/2627/00090		Date of Issue :		28/04/2026
Registration no.:		RWTLMOG/REG2627/00543		Condition of Sample :		Unsealed
Collection Point:		Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		School Motor Water (Akal Academy Purane Wala) / NA
Village :		Purane Wala		Habitation :		Purane Wala
Block:		Moga-I		District :		Moga
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.59@27°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	296	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	260	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	160	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	32	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	19	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	26	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method
12	Total Coliform(TC)	Absent	Shall not be detectable in any 100 ml sample	No relaxation	CFU/100 ml.	IS 15185 Membrane Filtration Method

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)


rwtlmoga@gmail.com

13	E-Coli	Absent	Shall not be detectable in any 100 ml sample	No relaxation	CFU/100 ml.	IS 15185 Membrane Filtration Method
----	--------	--------	--	---------------	-------------	-------------------------------------

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Ashish Kumar
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Moga

----- End of the Test Report -----

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)

rwtlmoga@gmail.com

TEST REPORT						
Name & Address of Customer : Akal Academy Puranewala VPO Purane Wala Tehsil & Distt Moga (Punjab)			Customer Reference No.		No : Ref. No. - Pum/175 Dated : 16/04/2026	
			Sample Submitted by		Harpreet singh	
			Date of Sample Receipt		24/04/2026	
			Analysis Starting Date		25/04/2026	
			Analysis completion Date		27/04/2026	
Discipline : Chemical Testing, Bacteriological Testing			Group: Water			
ULR No.:				Sample Type :		Treated Water
Test Report No.:		RWTLMOG/2627/00090		Date of Issue :		28/04/2026
Registration no.:		RWTLMOG/REG2627/00544		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles
Scheme/Source:		Not Mentioned(Not Mentioned)		Location/Depth :		School RO Water (Akal Academy Purane Wala) / NA
Village :		Purane Wala		Habitation :		Purane Wala
Block:		Moga-I		District :		Moga
Latitude :		Not Mentioned		Longitude:		Not Mentioned
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.83@27°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	<5	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	120	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	52	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	90	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	5	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	2	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	22	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method
12	Total Coliform(TC)	Absent	Shall not be detectable in any 100 ml sample	No relaxation	CFU/100 ml.	IS 15185 Membrane Filtration Method

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)


rwtlmoga@gmail.com

13	E-Coli	Absent	Shall not be detectable in any 100 ml sample	No relaxation	CFU/100 ml.	IS 15185 Membrane Filtration Method
----	--------	--------	--	---------------	-------------	-------------------------------------

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Ashish Kumar
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Moga

----- End of the Test Report -----